#### SECTION 08 80 00 - GLAZING

#### PART 1 - GENERAL

## 1.1 SYSTEM REQUIREMENTS

## A. Design Requirements:

- 1. At a minimum provide high-performance, low-e, heat-strengthened, insulating-glass units at all exterior glazed openings.
  - a. Basis-of-Design Exterior Glazing: Viracon, VE1-2M.
- 2. At all exterior glazed openings, provide glazing with low reflectivity.
- 3. Select and configure glazing to support daylighting wherever possible and appropriate.

# B. PERFORMANCE REQUIREMENTS

1. Engineering design of glass by Contractor.

## PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Glass Manufacturers: Subject to compliance with requirements, provide products from one of the following:
  - 1. AFG Industries, Inc.
  - 2. Guardian Glass.
  - 3. Pilkington North America.
  - 4. PPG Industries.
  - 5. Viracon.
- B. Fire-Protection-Rated Glazing Manufacturers: Subject to compliance with requirements, provide products from one of the following:
  - 1. InterEdge, Inc., a subsidiary of AFG Industries, Inc.
  - 2. Nippon Electric Glass Co., Ltd. (distributed by Technical Glass Products).
  - 3. Pilkington Group Limited (distributed by Technical Glass Products).
  - 4. Safti First; SuperLite C/P.
  - 5. Schott North America, Inc.
  - 6. Vetrotech Saint-Gobain.

#### 2.2 MONOLITHIC-GLASS TYPES

- A. Clear float glass: Use at all interior door and window locations not required to be safety glass or fire-protection-rated.
- B. Clear fully tempered float glass at all interior door and window locations where safety glass is required.
- C. Polished wired glass permitted where fire-protection-rated glass is required.

#### 2.3 INSULATING-GLASS TYPES

A. Insulating-Glass Units: Factory-assembled units consisting of sealed lites of glass separated by a dehydrated interspace, qualified according to ASTM E 2190. Use at all exterior glazed openings.

GLAZING 08 80 00 - 1

# 2.4 FIRE-PROTECTION-RATED GLAZING TYPES

A. Fire-Protection-Rated Glazing: Listed and labeled by a testing agency acceptable to authorities having jurisdiction, for fire-protection ratings indicated, based on testing according to NFPA 252 for door assemblies and NFPA 257 for window assemblies. Permitted in lieu of polished wired glass where fire-protection-rated glass is required.

PART 3 - EXECUTION (Not Applicable)

END OF SECTION 08 80 00

GLAZING 08 80 00 - 2