

SECTION 09 65 00 - RESILIENT FLOORING

PART 1 - GENERAL (Not Applicable)

PART 2 - PRODUCTS

2.1 RESILIENT BASE AND ACCESSORIES

- A. Resilient Base:
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Johnsonite.
 - b. Musson, R.C. Rubber Co.
 - c. Roppe Corporation, USA.
 - 2. Material Requirement: Rubber.
 - 3. Style: Cove at all locations.
 - 4. Minimum Thickness: 0.125 inch.
 - 5. Height: 4 inches.
 - 6. Lengths: Coils in manufacturer's standard lengths.
 - 7. Outside Corners: Preformed.
 - 8. Inside Corners: Preformed.
- B. Resilient Molding Accessory: Rubber.
 - 1. Edge Strips: 0.125 inch thick, 1 inch wide, with tapered or bullnose edge.
- C. Abrasive Strips: Self-adhesive, 1 inch wide, with aluminum oxide grit.

2.2 RESILIENT TILE

- A. Vinyl Composition Floor Tile:
 - 1. Class: Through pattern.
 - 2. Wearing Surface: Smooth.
 - 3. Thickness: 0.125 inch.
 - 4. Size: 12 by 12 inches.

2.3 RESILIENT SHEET FLOORING

- A. Vinyl Sheet Floor Covering: ASTM F 1303, Type I, Grade 1, with Class B backing.
 - 1. Thickness: 0.080 inch thick.
 - 2. Wearing Surface: Smooth.
 - 3. Sheet Width: As standard with manufacturer.
 - 1. Seaming Method: Heat welded at medical labs (BSL2); standard otherwise.
- B. Linoleum Floor Coverings:
 - 1. Sheet Flooring: In manufacturer's standard length by not less than 78 inches wide.
 - 2. Seaming Method: Heat welded at medical labs (BSL2); standard otherwise.
 - 3. Thickness: 0.08 inch.

2.4 INSTALLATION MATERIALS

- 1. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement based provided or approved by manufacturer for applications indicated and capable of taper to feather edge.
- 2. Adhesives: Water-resistant type recommended by manufacturer to suit resilient products and substrate conditions indicated.

3. Floor Polish: Provide stripper, sealer and polish recommended by the University Environmental Health and Safety (EHS) through the University Project Manager.

PART 3 - EXECUTION

3.1 CLEANING AND PROTECTION

- A. Floor Polish: Strip factory seal and apply finish recommended by the University EHS through the University Project Manager.

END OF SECTION 09 65 00