



University of Colorado  
Denver | Anschutz Medical Campus

**Facilities Management**

**Facilities Projects**

Campus Services Building  
1945 Wheeling Street  
Mail Stop F418  
Aurora, Colorado 80045  
o 303-724-0623  
f 303-724-0931

**R1 N Basement Reno. ABSL3 space  
Project Number – PN 22\_125861**

**June 10, 2022**

**ADDENDUM 1**

**QUESTIONS/RESPONSES:**

**See attached spreadsheet**

**END OF ADDENDUM**

**R1 ABSL Contractor Bid Questions**

6/10/2020

Number	Contractor	Date of Question	Question	Disipline	Design team Response	Date of Response
1	Rapid Restoration and Construction	6/9/2022	Will the owner be taking care of the commissioning for the controls? There are no specifications for temperature controls only a note "Control Scope Notes" on drawing M-001?	Mech - Cator Ruma	Cator, Ruma and Associates will be the commissioning agent, however Siemens will need to be involved to operate the control system for CRA and make necessary programming changes to ensure the BSL-3 space does not have a reversal of airflow for any given failure mode as prescribed in the BMBL.	6/10/2022