

FIRE ALARM STATISTICS FOR CU ANSCHUTZ MEDICAL CAMPUS 2019

Facility	Street Address	Total Alarms/ Building	Fire Number	Cause of Alarm	Number of Injuries Requiring Medical Treatment	Number of Deaths Related to Fire	Value of Property Damage Caused by Fire/Smoke
AD1/L15	12631 E. 17th Ave.	1	0	1). 1st Floor Smoke 1548t (Equipment Failure)	0	0	0
BDC/M20	1775 Aurora Ct.	0	0				
Bldg. 400/Q09	2469 E. 17th Pl.	0	0				
Bldg. 401/R09	1784 Racine St.	0	0				
Bldg. 402/S09	12474 E. 19th Ave.	0	0				
Bldg. 406/T09	12477 E. 19th Ave.	0	0				
Bldg. 407/U09	12454 E. 19th Pl.	0	0				
Fitzsimons Bldg./Q20	13001 E. 17th Pl.	2	0	1). False Alarm-Smoke (System Malfunction) 2). Basement Smoke Elev Lobby (No FD).	0	0	0
Bldg. 532/S21	12856 E. 19th Ave.	0	0				
Bldg. 533/R24	13001 E. 17th Pl.	0	0				
Bldg. 534/S25	13001 E. 17th Pl.	0	0				
Bldg. 610/Q34	13309 E. 17th Pl.	0	0				
Campus Services/T36	1945 N. Wheeling St.	0	0				
Central Utilities Plant/S34	13350 E. 19th Ave.	0	0				
Education One/P26	13070 E. 19th Ave.	0	0				
Education Two-North/P28	13120 E. 19th Ave.	0	0				
Education Two-South/L28	13121 E. 19th Ave.	0	0				
EH&S/R30-R31	13178 E. 19th Ave.	0	0				
Fire Station/X28	1997 Uvalda Ct.	0	0				
Fulginiti Center/R27	13080 E. 9th Ave.	0	0				

Health and Wellness Center/V08	12348 E. Montview Blvd.	0	0				
Health Sciences Library/V23	2950 E. Montview Blvd.	0	0				
Henderson Parking Structure/V17	12706 E. Montview Blvd.	0	0				
Nighthorse Campbell/M24	13055 E. 17th Ave.	5	0	1-4). 1st Floor Smoke 153Bm (Steam Related) 2). 1st Floor Smoke 153Bm (Steam Related).	0	0	0
PASCAL/P30	13188 E. 19th Ave.	0	0				
Perinatal Research Facility/AK32	13243 E. 23rd Ave.	4	0	1). False Alarm-Smoke (System Malfunction) 2). False Alarm-Smoke (System Malfunction) 3). False Alarm (Unknown) 4). False Alarm (Unknown)	0	0	0
School of Pharmacy/V20	12850 E. Montview Blvd.	1	0	1). 2nd Floor Smoke 2407F (Lab Hot Plate).	0	0	0
Research One-North/P18	12800 E. 19th Ave.	6	0	1). False Alarm (Facilities Work No FD) 2). Main Waterflow-False (No FD) 3). 1st Floor Smoke 1407 (Unknown). 4). Vivarium Waterflow DVD1 (No FD) 5). 6th Floor Waterflow (Facilities Work) 6). 7th Floor Smoke 7209 (False Alarm)	0	0	0
Research One-South/L18	12801 E. 17th Ave.	1	0	1). False Alarm (Contractor Work)	0	0	0
Research Two/P15	12700 E. 19th Ave.	3	0	1). False Alarm (Unknown). 2). Pressure Release Valve/Steam Leak (No FD) 23). 5th Floor Smoke (Hot Plate).	0	0	0

School of Dental Med./L26	13065 E. 17th Ave.	4	1	1). Alcohol Fire/Extinguished by student 2). Smoke Trip (Dust). 3). 1st Floor Smoke 101m (Elev. Equip. Failure) 4). 1st Floor Smoke 122 (Steam Related).	1	0	0
Total CU Anschutz 2019		27	1		1	0	0

FIRE ALARM STATISTICS FOR CU DENVER CAMPUS 2019

Facility	Street Address	Total Alarms/ Building	Fire Number	Cause of Alarm	Number of Injuries Requiring Medical Treatment	Number of Deaths Related to Fire	Value of Property Damage Caused by Fire/Smoke
Academic Building One/ABI	1201 Larimer St.	0	0				
CU Denver Bldg./CU	1250 14th St.	0	0				
CU Denver Business School	1475 Lawrence St.	2	0	1). False Alarm (Pull Station) 2). False	0	0	0
Lawrence Street Center/LW	1380 Lawrence St.	2	0	1). No Details. 2). 8th Floor Smoke (Contractor Work)	0	0	0
Lola & Rob Salazar Student Wellness	1355 12th St.	0	0				
Total CU Denver 2019		4	0		0	0	0