



CU Anschutz R2 Basement Fix Paint with FRP Phase 2 Advertisement for Bids for Design/Bid/Build

Project Number – 21-164359

Monday, April 25, 2022

ADDENDUM 1

1. Work Area 8: Elevator Alcove Walls shall be excluded from the bid.

QUESTIONS/RESPONSES:

1. Who signs off that all detached or loose paint has been removed prior to application of the FRP Panels?

Response: Refer to plan note 7 on A2.01 and SIM. The contractor is responsible for removing the sections of paint that have detached from the wall. Photos should be taken of substrate to document that all loose paint was removed. A formal inspection will not be performed.

2. Who removes the building signage?

Response: Refer to plan note 4 on A2.01 and SIM. The contractor is responsible for documenting any wall mounted items, removing for the installation of FRP, and ensuring the items are re-installed in the same location.

Attachments: Pre-Submittal Meeting Attendance List

END OF ADDENDUM 1

University of Colorado Denver

Mandatory Site Visit Attendance List

R2 Bsmt Fix Paint Phase 2 PN21-164359

Project Name

April 18, 2022

Date

<u>Name</u>	<u>Firm</u>	<u>Phone</u>	<u>E-mail Address</u>
NATHAN WAIT	MILLO CONSTRUCTION	303 444	nathan@milloconstruction.com
Justin Gilmore	Gilmore Construction	3.502.7814	jtgilmore@gilmorecc.com
Justin Daniel	Spartan Construction	719-425-6221	jdjustin@spartancolorado.com
Paul Hegarty	Spartan Construction	303-907-8316	PHegarty@SpartanColorado.com
CHAD GREEN	BAUEN STUDIOS	303-552-9573	cgreen@bauenstudios.com
Matt Wedgeworth	Metro Reno Serv	720.419.8045	MWedgeworth@metrorenoservice.com