

## FIRE ALARM STATISTICS FOR CU ANSCHUTZ MEDICAL CAMPUS 2020

| Facility                    | Street Address       | Total Alarms/<br>Building | Fire<br>Number | Cause of Alarm  | Number of Injuries<br>Requiring Medical<br>Treatment | Number of<br>Deaths Related<br>to Fire | Value of Property<br>Damage Caused<br>by Fire/Smoke |
|-----------------------------|----------------------|---------------------------|----------------|---|--|--|---|
| A01/L15                     | 12631 E. 17th Ave.   | 0                         | 0              |   |  |  |   |
| B0C/M20                     | 1775 Aurora Ct.      | 3                         | 0              | 1). False Alarm-Smoke (Steam) 2). False Alarm-Smoke (Steam). 3). 1st floor smoke-(false).   | 0  | 0                                      | 0   |
| Bldg. 400/Q09               | 2469 E. 17th Pl.     | 0                         | 0              |   |  |  |   |
| Bldg. 401/R09               | 1784 Racine St.      | 0                         | 0              |   |  |  |   |
| Bldg. 402/S09               | 12474 E. 19th Ave.   | 0                         | 0              |   |  |  |   |
| Bldg. 406/T09               | 12477 E. 19th Ave.   | 0                         | 0              |   |  |  |   |
| Bldg. 407/U09               | 12454 E. 19th Pl.    | 0                         | 0              |   |  |  |   |
| Fitzsimons Bldg./Q20        | 13001 E. 17th Pl.    | 4                         | 0              | 1). 2nd Floor Smoke (Light Ballast) 2). Main Lobby Smoke (dust from workers). 3). Smoke (dust). 4). 2nd floor pull station (false). | 0  | 0                                      | 0   |
| Bldg. 532/S21               | 12856 E. 19th Ave.   | 0                         | 0              |   |  |  |   |
| Bldg. 533/R24               | 13001 E. 17th Pl.    | 0                         | 0              |   |  |  |   |
| Bldg. 534/S25               | 13001 E. 17th Pl.    | 0                         | 0              |   |  |  |   |
| Bldg. 610/Q34               | 13309 E. 17th Pl.    | 0                         | 0              |   |  |  |   |
| Campus Services/T36         | 1945 N. Wheeling St. | 2                         | 1              | 1). First Floor Smoke (false). 2). Grass Fire   | 0  | 0                                      | 0   |
| Central Utilities Plant/S34 | 13350 E. 19th Ave.   | 0                         | 0              |   |  |  |   |
| Education One/P26           | 13070 E. 19th Ave.   | 1                         | 0              | 1). Fireworks False   | 0  | 0                                      | 0   |
| Education Two-North/P28     | 13120 E. 19th Ave.   | 0                         | 0              |   |  |  |   |
| Education Two-South/L28     | 13121 E. 19th Ave.   | 1                         | 0              | 4th Floor Smoke (4207T bad motor).  | 0  | 0                                      | 0   |
| EH&S/R30-R31                | 13178 E. 19th Ave.   | 0                         | 0              |   |  |  |   |

|                                  |                         |    |   |  |   |   |   |
|----------------------------------|-------------------------|----|---|--|---|---|---|
| Fire Station/X28                 | 1997 Uvalda Ct.         | 0  | 0 |  |   |   |   |
| Fulginiti Center/R27             | 13080 E. 9th Ave.       | 0  | 0 |  |   |   |   |
| Health and Wellness Center/V08   | 12348 E. Montview Blvd. | 1  | 0 | 2nd Floor Smoke (freezer refrigerant leak).  | 0 | 0 | 0 |
| Health Sciences Library/V23      | 2950 E. Montview Blvd.  | 0  | 0 |  |   |   |   |
| Henderson Parking Structure/V17  | 12706 E. Montview Blvd. | 1  | 0 | 1). False Alarm-Smoke (Smoke from snowmelt machine).   | 0 | 0 | 0 |
| Nighthorse Campbell/M24          | 13055 E. 17th Ave.      | 0  | 0 |  |   |   |   |
| PASCAL/P30                       | 13188 E. 19th Ave.      | 0  | 0 |  |   |   |   |
| Perinatal Research Facility/AK32 | 13243 E. 23rd Ave.      | 0  | 0 |  |   |   |   |
| School of Pharmacy/V20           | 12850 E. Montview Blvd. | 0  | 0 |  |   |   |   |
| Research One-North/P18           | 12800 E. 19th Ave.      | 0  | 0 |  |   |   |   |
| Research One-South/L18           | 12801 E. 17th Ave.      | 1  | 0 | 1). False Alarm 9th floor (Steam from experiment))   | 0 | 0 | 0 |
| Research Two/P15                 | 12700 E. 19th Ave.      | 12 | 0 | 1). Vivarium Smoke (Steam Leak). 2). False Smoke Mech Room 0403 x 4. 3). 104908 Student burned plastic. 4). M300M False (Dust). 5). Fireworks false Viv past lobby. 6). Waterflow N. Stairs (contractor error). 7). Viv Smoke (dust). 8). Fireworks - Steam in interstitial. 9). Vivarium Smoke. | 0 | 0 | 0 |
| School of Dental Med./L26        | 13065 E. 17th Ave.      | 1  | 0 | 1). 3rd Floor Smoke -false.  | 0 | 0 | 0 |
| Total CU Anschutz 2020           |                         | 27 | 1 |  | 0 | 0 | 0 |

## FIRE ALARM STATISTICS FOR CU DENVER CAMPUS 2020

| Facility                            | Street Address    | Total Alarms/<br>Building | Fire<br>Number | Cause of Alarm  | Number of Injuries<br>Requiring Medical<br>Treatment | Number of Deaths<br>Related to Fire | Value of Property<br>Damage Caused by<br>Fire/Smoke |
|-------------------------------------|-------------------|---------------------------|----------------|---|--|-------------------------------------|---|
| Academic Building One/ABI           | 1201 Larimer St.  | 0                         | 0              |   |  |                                     |   |
| CU Denver Bldg./CU                  | 1250 14th St.     | 0                         | 0              |   |  |                                     |   |
| CU Denver Business School           | 1475 Lawrence St. | 0                         | 0              |   |  |                                     |   |
| Lawrence Street Center/LW           | 1380 Lawrence St. | 3                         | 0              | 1). False Alarm-Smoke 2).<br>False Alarm-Smoke. 3).<br>False. | 0  | 0                                   | 0   |
| Lola & Rob Salazar Student Wellness | 1355 12th St.     | 0                         | 0              |   |  |                                     |   |
| Lynx Crossing                       | 318 Walnut St.    | 0                         | 0              |   |  |                                     |   |
|                                     |                   |                           |                |   |  |                                     |   |
|                                     |                   |                           |                |   |  |                                     |   |
|                                     |                   |                           |                |   |  |                                     |   |
|                                     |                   |                           |                |   |  |                                     |   |
|                                     |                   |                           |                |   |  |                                     |   |
|                                     |                   |                           |                |   |  |                                     |   |
| Total CU Denver 2020                |                   | 3                         | 0              |   | 0  | 0                                   | 0   |